

GASOLINE TANKS

GREATER THAN 550 GAL. & LESS THAN 40,000 GAL.

Use this form only if tanks meet all of the following criteria:

- Tanks have a capacity of greater than 550 gallons and less than 40,000 gallons; and
- Tanks are used exclusively for fueling of implements of husbandry

Applicable Requirements and Compliance Certification (Farms located in Yolo-Solano Air Quality Management District)

This form may be used in lieu of standard form "Part D – Compliance Certification." If you choose to use this form, it must be accompanied by the Applicable Requirements and Compliance Certification form for General Farming Operations in the Yolo-Solano AQMD, and any other equipment and operation forms as applicable. Refer to the attached Yolo-Solano AQMD – Part D instructions for more information.

1. Equipment Description: Describe gasoline tanks.			
	Tank Designation	Capacity (gallons)	Above-ground or underground
Example	South Tank One	4,000	Aboveground
1.			
2.			
3.			
4.			
5.			

2. Applicable Requirement(s) Applicable Rule, Regulation, & Section number that the gasoline tank must comply with.	3. Method used for determining compliance. This is the primary method used to determine the tank is in compliance with the applicable requirement.	4. Compliance Status for all units listed above (Use a separate form for units with varying compliance status)
<p>RULE 2.21 – VAPOR CONTROL FOR ORGANIC LIQUID STORAGE AND TRANSFER (March 23, 1994)</p> <p>303. Each storage tank shall be equipped with a submerged fill pipe and an ARB certified Phase I vapor recovery system.</p> <p>304. Organic liquids subject to this Rule shall not be spilled, discarded to sewers, stored in open containers, or handled in any other manner that would result in evaporation to the atmosphere. Spills and leaks resulting from maintenance or repair operations shall not apply provided proper operating practices are employed to minimize evaporation to the atmosphere.</p> <p>500. The following records shall be maintained and made available to the District upon request:</p> <ul style="list-style-type: none"> a. name, address and type of facility, b. monthly and annual throughput, and c. size and number of storage containers. 	<p>1. I have knowledge that a submerged fill pipe and ARB certified Phase I vapor recovery system has been installed, <u>and</u></p> <p>2. I have knowledge that gasoline is not spilled, discarded to sewers, stored in open containers, or handled in any other manner that would result in evaporation to the atmosphere, <u>and</u></p> <p>3. I have knowledge that I maintain gasoline throughput records and these records are maintained on the premises for a period of at least five years.</p>	<div style="margin-bottom: 20px;"> <input type="checkbox"/> in compliance with rule 2.21 at this time and I will continue to comply with all requirements. </div> <div> <input type="checkbox"/> not in compliance with rule 2.21 at this time, but I will be by: <u> </u>/<u> </u>/<u> </u> (submit plan per instructions) </div>